PACKAGED UNITS KITS AND ACCESSORIES

506207-03 7/2024 Supersedes 506207-02

COLD WEATHER KIT

INSTALLATION INSTRUCTIONS FOR COLD WEATHER KIT USED ON LG/LD 024-074 & SG 36-60 GAS PACKAGED UNITS

AWARNING

Improper installation, adjustment, alteration, ser vice or maintenance can cause property damage, personal injury or loss of life. Installation and ser vice must be performed by a licensed professional HVAC installer or equivalent, service agency, or the gas supplier.

AWARNING



Electric Shock Hazard. Can cause injury or death. Unit must be grounded in accordance with national and local codes. Line voltage is present at all components when unit is not in operation on units with single-pole contactors. Disconnect all remote electric power supplies before opening access panel. Unit may have multiple power supplies.

Shipping and Packing List

Package 1 of 1 contains:

- 1- Heater assembly
- 1- Control assembly
- 1- Wire harness
- 4- #10 Sheet metal screws

Application

The cold weather kit heats the compressor compartment to allow gas valve operation during low outdoor temperatures.

See TABLE 1 for usage.

TABLE 1

VOLTAGE	UNIT	KIT	IMAGE
P/Y		604263-04; 21Z17	
G/M	LG/LD	604263-05; 21Z18	FIGURE 3 & 4
J		604263-06; 21Z19	
G	SG	604263-08; 31A62	FIGURE 5
J		604263-09; 31A63	

Installation

ACAUTION

As with any mechanical equipment, contact with sharp sheet metal edges can result in personal in jury. Take care while handling this equipment and wear gloves and protective clothing.

- Disconnect all power to unit and open compressor access panel.
- 2 Install the heater and control assembly in the compressor compartment as shown in FIGURE 1 and FIGURE 2. Secure with provided screws.
- 3 Make harness and wire connections as shown in FIGURE 3. Refer to FIGURE 4 and FIGURE 5 for component layout details.
- 4 Route wires away from copper plumbing. Do not leave any wires on base pan.




FIGURE 1




FIGURE 2



Operation

When ambient temperature drops below 20°F (-7°C), S61 closes. When ambient temperature drops below -10°F (-23°C), S60 closes to energize K125 and bring on HR6 heater.

When ambient temperature rises to 20°F (-7°C), S60 opens to de-energize HR6 heater.

When ambient temperature drops below -20°F (-29°C), S59 opens to disable GV1 gas valve. S59 closes to allow heating when temperature rises to 10°F (-12°C).




FIGURE 3




FIGURE 4




FIGURE 5